



# Environmental Control Systems, Inc.

Environmental Engineers and Management Consultants

June 17, 2021

Mr. Ken Morris  
Director of Facilities  
Great Valley School District  
47 Church Road  
Malvern, PA 19355

Re: Lead in Drinking Water Sampling Results

Dear Mr. Morris:

Drinking water outlets in the Great Valley School District were tested for Lead in Drinking Water on June 9, 2021. "First Draw" samples were collected from various outlets in accordance with EPA protocol listed in the 3T's for Reducing Lead in Drinking Water in Schools, revised October 2018.

*Analysis was performed by EMSL, an EPA accredited laboratory. Results are based on PDE and EPA recommended action level which is 15 parts per billion (ppb) for lead in schools based on a 250 ml sample.*

**All results are Non-Detect which is under the PA Act 39, PDE and EPA action limit of 15 ppb.**

Your District has shown that implementing a "Flushing Program" works!

Cordially,

Barbara Lippmann  
President

Enclosure: